

**NOTICE TO MECHANICAL CONTRACTORS WITH
REFERENCE TO REQUIREMENTS RELATED TO
MECHANICAL AIR CONDITIONING CHANGEOUTS**

**FLORIDA BUILDING CODE (FBC)
CHAPTER 13 ENERGY EFFICIENCY**

Outdoor and indoor units that are not designed to be operated together must meet the U.S. Department of Energy certification requirements contained in FBC Section 13-607.A.B.C.3.1.1. This match may be verified by any one of the following methods:

- Air Conditioning and Refrigeration Institute (ARI) data**
- Test from an accredited Laboratory (example: ARL labs)**
- Data furnished by the manufacturer**
- Letter from a State of Florida licensed Professional Engineer**